

## DEPUTY DIRECTOR, HEALTH SERVICES

## STATE PUBLIC HEALTH LABORATORY, PUNE.

Near St. Mary School And Church, Pune 411001

Telephone - Office :- (020) 263300225 Ext. 223

Email: statehealthlab@gmail.com

HEALTH SERVICES

DATE: 12/12/2023. NO. SPHL PUNE /Desk -79 / 1223 / 2023.

mdhere Road, Tal – Shirur, Dist – Pune 412216.	
Dated :- 06 / 12 /2023	
Date of Examination :- 08/12/2023 Onwards	

SR. NO	TEST PARAMETER	S.No 1 ( P-613) Ro Water	BIS Specifications 10500 : 2012 Normal Values	
			Desirable limit	Permissible limit
1	Physical Appearence	Clear	222	
2	Odour	agreeable	agreeable	agreeable
3	Turbidity ( as N.T.U. )	0.32	1.0	5.0
4	pH Value	7.36	6.5 to 8.5	No relaxation
5	Chlorides ( as Cl )	13.89	250	1000
6	Nitrates (as No3)	0.094	45	No relaxation
7	Total Hardness ( as Caco3 )	12.12	200	600
8	Alkalinity (as Caco3)	16.14	200	600
9	Total Dissolved Solids	48.6	500	2000
10	Iron ( as Fe )	ND	1.0	No relaxation
4.0	armit ( mo e.e.)		0.0000000000000000000000000000000000000	

ND

ND :- Not detected.

This report is restricted only for the sample /s submitted to this laboratory.

It is presumed that the representative sample from the source is sent for analysis.

This Sample /s is /are not collected by this laboratory.

Fluoride (as F)

Remark- Above Sample No. -1 is chemically fit for drinking purpose on the basis of analysed parameters only.

However, this water source can be used for drinking purpose only after proper treatment, disinfection & ascertaining its bacteriological quality frequently or regularly.

Forwarded with compliments to :- Jaywant Public School, Sanaswadi, Talegaon dhamdhere Road, Tal - Shirur, Dist - Pune 412216.

600 /-Fees 8314691 Receipt No. 06/12/2023 Date

State Public Health Laboratory, Pune (Water & Food Section)